

R710. Public Safety, Fire Marshal.

R710-9. Rules Pursuant to the Utah Fire Prevention Law.

R710-9-1. Title, Authority, and Adoption of Codes.

1.1 These rules shall be known as the "Rules Pursuant to the Utah Fire Prevention Law", and may be cited as such, and will be hereafter referred to as "these rules".

1.2 These rules are promulgated in accordance with Title 53, Chapter 7, Section 204, Utah Code Annotated 1953, as amended.

1.3 These rules are adopted by the Utah Fire Prevention Board to provide minimum rules for safeguarding life and property from the hazards of fire and explosion, for board meeting conduct, procedures to amend incorporated references, establish board subcommittees, enforcement of the rules of the State Fire Marshal, and deputizing Special Deputy State Fire Marshals.

1.4 There is adopted as part of these rules the following code which is incorporated by reference:

1.4.1 International Fire Code (IFC), 2003 edition, excluding appendices, as promulgated by the International Code Council, Inc., except as amended by provisions listed in R710-9-6, et seq.

1.5 There is further adopted as part of these rules the following codes which are also incorporated by reference and supercede the adopted standards listed in the International Fire Code, 2003 edition, Chapter 45, Referenced Standards, as follows:

1.5.1 National Fire Protection Association (NFPA), NFPA 10, Standard for Portable Fire Extinguishers, 2002 edition, except as amended by provisions listed in R710-9-6, et seq.

1.5.2 National Fire Protection Association (NFPA), NFPA 13, Standard for Installation of Sprinkler Systems, 2002 edition, except as amended by provisions listed in R710-9-6, et seq.

1.5.3 National Fire Protection Association (NFPA), NFPA 13D, Standard for the Installation of Sprinkler Systems in One and Two Family Dwellings and Manufactured Homes, 2002 edition, except as amended by provisions listed in R710-9-6, et seq.

1.5.4 National Fire Protection Association (NFPA), NFPA 13R, Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and including Four Stories in Height, 2002 edition, except as amended by provisions listed in R710-9-6, et seq.

1.5.5 National Fire Protection Association (NFPA), NFPA 70, National Electric Code, 2002 edition, as adopted by the Uniform Building Standards Act, Title 58. Chapter 56, Section 4, Utah Code Annotated 1953 and the Utah Administrative Code R156-56-701. Wherever there is a section, figure or table in the International Fire Code (IFC) that references "ICC Electrical Standard", that reference shall be replaced with "National Electric Code".

1.5.6 National Fire Protection Association (NFPA), NFPA 72, National Fire Alarm Code, 2002 edition, except as amended in provisions listed in R710-9-6, et seq.

1.5.7 National Fire Protection Association (NFPA), NFPA 101, Life Safety Code, 2003 edition, except as amended in provisions listed in R710-9-6, et seq. Wherever there is a section, figure or table in NFPA 101 that references "NFPA 5000 - Building Construction and Safety Code", that reference shall be replaced with the "International Building Code".

1.5.8 National Fire Protection Association (NFPA), NFPA 160, Standard for Flame Effects Before an Audience, 2001 edition, except as amended by provisions listed in R710-9-6, et seq.

1.6 National Fire Protection Association (NFPA), NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, 2001 edition, except as amended by provisions listed in R710-9-6, et seq.

R710-9-2. Definitions.

- 2.1 "Appreciable Depth" means a depth greater than 1/4 inch.
- 2.2 "Authority Having Jurisdiction (AHJ)" means the State Fire Marshal, his authorized deputies, or the local fire enforcement authority.
- 2.3 "Board" means Utah Fire Prevention Board.
- 2.4 "Division" means State Fire Marshal.
- 2.5 "ICC" means International Code Council, Inc.
- 2.6 "IFC" means International Fire Code.
- 2.7 "Institutional occupancy" means asylums, mental hospitals, hospitals, sanitariums, homes for the aged, residential health care facilities, children's homes or institutions, or any similar institutional occupancy.
- 2.8 "LFA" means Local Fire Authority.
- 2.9 "NFPA" means National Fire Protection Association.
- 2.10 "Place of assembly" means where 50 or more people gather together in a building, structure, tent, or room for the purpose of amusement, entertainment, instruction, or education.
- 2.11 "SFM" means State Fire Marshal or authorized deputy.
- 2.12 "Sub-Committee" means Fire Prevention Board Budget Sub-Committee or Amendment Sub-Committee.
- 2.13 "UCA" means Utah Code Annotated, 1953.

R710-9-3. Conduct of Board Members and Board Meetings.

- 3.1 Board meetings shall be presided over and conducted by the chairman and in his absence the vice chairman or the chairman's designee.
- 3.2 A quorum shall be required to approve any action of the Board.
- 3.3 The chairman of the Board and Board members shall be entitled to vote on all issues considered by the Board. A Board member who declares a conflict of interest or where a conflict of interest has been determined, shall not vote on that particular issue.
- 3.4 Meetings of the Board shall be conducted in accordance with an agenda, which shall be submitted to the members by the division, not less than 21 days before the regularly scheduled Board meetings.
- 3.5 Public notice of Board meetings shall be made by the Division as prescribed in UCA Section 52-4-6.
- 3.6 The division shall provide the Board with a secretary who shall prepare minutes and shall perform all secretarial duties necessary for the Board to fulfill its responsibility. The minutes of Board meetings shall be completed and sent to Board members at least 14 days prior to the scheduled Board meeting.
- 3.7 A Board members standing on the Board shall come under review after two unexcused absences in one year from regularly scheduled board meetings. The Board members name shall be submitted to the governors office for status review.

R710-9-4. Deputizing Persons to Act as Special Deputy State Fire Marshals.

- 4.1 Special deputy state fire marshals may be appointed by the SFM to positions of expertise within the regular scope of the Fire Marshal's Office.
- 4.2 Pursuant to Section 53-7-101 et seq., special deputy state fire marshals may also be appointed to assist the Fire Marshal's Office in establishing and maintaining minimum fire prevention standards in those occupancy classifications listed in the International Fire Code.
- 4.3 Special deputy state fire marshals shall be appointed after review by the State Fire Marshal in regard to their qualifications and the overall benefit to the Office of the State Fire Marshal.
- 4.4 Special deputy state fire marshals shall be appointed by completing an oath and shall be appointed for a specific period of time.
- 4.5 Special deputy state fire marshals shall have a picture identification card

and shall carry that card when performing their assigned duties.

R710-9-5. Procedures to Amend the International Fire Code.

5.1 All requests for amendments to the IFC shall be submitted to the division on forms created by the division, for presentation to the Board at the next regularly scheduled Board meeting.

5.2 Requests for amendments received by the division less than 21 days prior to any regularly scheduled meeting of the Board may be delayed in presentation until the next regularly scheduled Board meeting.

5.3 Upon presentation of a proposed amendment, the Board shall do one of the following:

5.3.1 accept the proposed amendment as submitted or as modified by the Board;

5.3.2 reject the proposed amendment;

5.3.3 submit the proposed amendment to the Board Amendment Subcommittee for further study; or

5.3.4 return the proposed amendment to the requesting agency, accompanied by Board comments, allowing the requesting agency to resubmit the proposed amendment with modifications.

5.4 The Board Amendment Subcommittee shall report its recommendation to the Board at the next regularly scheduled Board meeting.

5.5 The Board shall make a final decision on the proposed amendment at the next Board meeting following the original submission.

5.6 The Board may reconsider any request for amendment, reverse or modify any previous action by majority vote.

5.7 When approved by the Board, the requesting agency shall provide to the division within 45 days, the completed ordinance.

5.8 The division shall maintain a list of amendments to the IFC that have been granted by the Board.

5.9 The division shall make available to any person or agency copies of the approved amendments upon request, and may charge a reasonable fee for multiple copies in accordance with the provisions of UCA, 63-2-203.

R710-9-6. Amendments and Additions.

The following amendments and additions are hereby adopted by the Board for application statewide:

6.1 Administration

6.1.1 IFC, Chapter 1, Section 102.3 is deleted and rewritten as follows: No change shall be made in the use or occupancy of any structure that would place the structure in a different division of the same group or occupancy or in a different group of occupancies, unless such structure maintains a reasonable level of fire and life safety and the change to use or occupancy does not create a distinct hazard to life or property as determined by the AHJ.

6.1.2 IFC, Chapter 1, Section 102.4 is deleted and rewritten as follows: The design and construction of new structures shall comply with the International Building Code. Repairs, alterations and additions to existing structures are allowed when such structure maintains a reasonable level of fire and life safety and the change does not create a distinct hazard to life or property as determined by the AHJ.

6.1.3 IFC, Chapter 1, Section 102.5 is deleted and rewritten as follows: The construction, alteration, repair, enlargement, restoration, relocation or movement of existing buildings or structures that are designated as historic buildings are allowed when such historic structures maintains a reasonable level of fire and life safety and the change does not create a distinct hazard to life or property as determined by the AHJ.

6.1.4 IFC, Chapter, 1, Section 102.4 is amended as follows: On line three after

the words "Building Code." add the following sentence: "The design and construction of detached one- and two-family dwellings and multiple single-family dwellings (town houses) not more than three stories above grade plane in height with a separate means of egress and their accessory structures shall comply with the International Residential Code."

6.1.5 IFC, Chapter 1, Section 109.2 is amended as follows: On line three after the words "is in violation of this code," add the following "or other pertinent laws or ordinances".

6.2 Definitions

6.2.1 IFC, Chapter 2, Section 202, Educational Group E, Day care is amended as follows: On line three delete the word "five" and replace it with the word "four".

6.2.2 IFC, Chapter 2, Section 202, Institutional Group I, Group I-1 is amended to add the following: Add "Type 1" in front of the words "Assisted living facilities".

6.2.3 IFC, Chapter 2 Section 202, Institutional Group I, Group I-2 is amended as follows: On line three delete the word "five" and replace it with the word "three". After "Detoxification facilities" delete the rest of the paragraph, and add the following: "Ambulatory surgical centers with two or more operating rooms where care is less than 24 hours, Outpatient medical care facilities for ambulatory patients (accommodating more than five such patients in each tenant space) which may render the patient incapable of unassisted self-preservation, and Type 2 assisted living facilities.

Type 2 assisted living facilities with five or fewer persons shall be classified as a Group R-4. Type 2 assisted living facilities with at least six and not more than 16 residents shall be classified as a Group I-1 facility.

6.2.4 IFC, Chapter 2, Section 202, Institutional Group I, Group I-4, day care facilities, Child care facility is amended as follows: On line three delete the word "five" and replace it with the word "four". Also on line two of the Exception after Child care facility delete the word "five" and replace it with the word "four".

6.2.5 IFC, Chapter 2, Section 202 General Definitions, Occupancy Classification, Residential Group R-1 is amended to add the following: Exception: Boarding houses accommodating 10 persons or less shall be classified as Residential Group R-3.

6.2.6 IFC, Chapter 2, Section 202 General Definitions, Occupancy Classification, Residential Group R-2 is amended to add the following: Exception: Boarding houses accommodating 10 persons or less shall be classified as Residential Group R-3.

6.3 General Precautions Against Fire

6.3.1 IFC, Chapter 3, Section 304.1.2 is amended to delete the following sentence: "Vegetation clearance requirements in urban-wildland interface areas shall be in accordance with the International Urban/Wildland Interface Code."

6.3.2 IFC, Chapter 3, Section 311.1.1 is amended as follows: On line ten delete the words "International Property Maintenance Code and the" from this section.

6.3.3 IFC, Chapter 3, Section 315.2.1 is amended to add the following: Exception: Where storage is not directly below the sprinkler heads, storage is allowed to be placed to the ceiling on wall mounted shelves that are protected by fire sprinkler heads in occupancies meeting classification as light or ordinary hazard.

6.4 Elevator Recall and Maintenance

6.4.1 IFC, Chapter 6, Section 607.3 is deleted and rewritten as follows: Firefighter service keys shall be kept in a "Supra - Stor-a-key" elevator key box or similar box with corresponding key system that is adjacent to the elevator for immediate use by the fire department. The key box shall contain one key for each elevator and one key for lobby control.

6.5 Building Services and Systems

6.5.1 IFC, Chapter 6, Section 610.1 is amended to add the following: On line three after the word "Code" add the words "and NFPA 96".

6.6 Record Drawings

6.6.1 IFC, Chapter 9, Section 901.2.1 is amended to add the following: The code official has the authority to request record drawings ("as built") to verify any

modifications to the previously approved construction documents.

6.6.2 IFC, Chapter 9, Section 902.1 Definitions, RECORD DRAWINGS is deleted and rewritten as follows: Drawings ("as built") that document all aspects of a fire protection system as installed.

6.7 Fire Protection Systems

6.7.1 Inspection and Testing of Automatic Fire Sprinkler Systems

The owner or administrator of each building shall insure the inspection and testing of water based fire protection systems as required in IFC, Chapter 9, Section 901.6.

6.7.2 IFC, Chapter 9, Section 903.2.7 Group R, is amended to add the following: Exception: Detached one- and two-family dwellings and multiple single-family dwellings (townhouses) constructed in accordance with the International Residential Code for one- and two-family dwellings.

6.7.3 IFC, Chapter 9, Section 903.2.7 is amended to add the following: Exception: Group R-4 fire areas not more than 4500 gross square feet and not containing more than 16 residents, provided the building is equipped throughout with an approved fire alarm system that is interconnected and receives its primary power from the building wiring and a commercial power system.

6.7.4 IFC, Chapter 9, Section 903.6 is amended to add the following subsection: 903.6.2 Commercial cooking operation suppression. Automatic fire sprinkler systems protecting commercial kitchen exhaust hood and duct systems with appliances that generate appreciable depth of cooking oils shall be replaced with a UL300 listed system by May 1, 2004.

6.7.5 IFC, Chapter 9, Section 903.6 is amended to add the following subsection: 903.6.3 Dry chemical hood system suppression. Existing automatic fire-extinguishing systems using dry chemical that protect commercial kitchen exhaust hood and duct systems shall be removed and replaced with a UL300 listed system by January 1, 2006.

6.7.6 IFC, Chapter 9, Section 903.6 is amended to add the following subsection: 903.6.4 Wet chemical hood system suppression. Existing wet chemical fire-extinguishing systems not UL300 listed and protecting commercial kitchen exhaust hood and duct systems shall be removed, replaced or upgraded to a UL300 listed system by January 1, 2006.

6.7.7 IFC, Chapter 9, Section 903.6 is amended to add the following subsection: 903.6.5 Group A-2 occupancies. An automatic fire sprinkler system shall be provided throughout Group A-2 occupancies where indoor pyrotechnics are used.

6.7.8 IFC, Chapter 9 Section 904.11.6.4 is amended to add the following: Automatic fire extinguishing systems located in occupancies where usage is limited and less than six consecutive months, may be serviced annually if the annual service is conducted immediately before the period of usage, and approval is received from the AHJ.

6.7.9 IFC, Chapter 9, 906.2 is amended to add the following exception: 2. 30 day inspections shall not be required and maintenance shall be permitted to be once every three years for dry chemical or halogenated agent portable fire extinguishers that are connected to a supervised listed electronic monitoring system that meet the following: 2.1 Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged, and unobstructed; 2.2 Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal; 2.3 The extinguishers shall be installed inside of a building or cabinet in a non-corrosive environment; 2.4 Electronic monitoring devices and supervisory circuits shall be tested every three years when extinguisher maintenance is performed; and, 2.5 A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to ensure that hydrostatic tests are conducted at the frequency required by NFPA 10.

6.7.10 NFPA, Standard 10, Section 6.2.1 is amended to add the following sentence: The use of a supervised listed electronic monitoring system shall be permitted to satisfy the 30 day fire extinguisher interval inspection requirement.

6.7.11 NFPA, Standard 10, Section 6.3.1 is amended to add the following: Fire

extinguishers that are connected to a supervised listed electronic monitoring system are allowed to have the maintenance intervals extended to 3 years.

6.8 Backflow Protection

6.8.1 The potable water supply to automatic fire sprinkler systems and standpipe systems shall be protected against backflow in accordance with the International Plumbing Code as amended in the Utah Administrative Code, R156-56-707.

6.9 Retroactive Installations of Automatic Fire Alarm Systems in Existing Buildings

6.9.1 IFC, Chapter 9, Sections 907.3.1.1, 907.3.1.2, 907.3.1.3, 907.3.1.4, 907.3.1.5, 907.3.1.6, 907.3.1.7, and 907.3.1.8 are deleted.

6.10 Smoke Alarms

6.10.1 IFC, Chapter 9, Section 907.3.2 is amended to add the following: On line three after the word "occupancies" add "and detached one- and two-family dwellings and multiple single-family dwellings (townhouses)".

6.10.2 IFC, Chapter 9, Section 907.3.2.3 is amended to add the following: On line one after the word "occupancies" add "and detached one- and two-family dwellings and multiple single-family dwellings (townhouses)".

6.10.3 IFC, Chapter 9, Section 907.20.5 is amended to add the following sentences: Increases in nuisance alarms shall require the fire alarm system to be tested for sensitivity. Fire alarm systems that continue after sensitivity testing with unwarranted nuisance alarms shall be replaced as directed by the AHJ.

6.11 Means of Egress

6.11.1 IFC, Chapter 10, Section 1008.1.8.3 is amended to add the following: 5. Doors in Group I-1 and I-2 occupancies, where the clinical needs of the patients require specialized security measures for their safety, approved access controlled egress may be installed when all the following are met: 5.1 The controlled egress doors shall unlock upon activation of the automatic fire sprinkler system or the automatic fire detection system. 5.2 The facility staff can unlock the controlled egress doors by either sensor or keypad. 5.3 The controlled egress doors shall unlock upon loss of power. 6. Doors in Group I-1 and I-2 occupancies, where the clinical needs of the patients require approved, listed delayed egress locks, they shall be installed on doors as allowed in IFC, Section 1008.1.8.6.

6.11.2 IFC, Chapter 10, Section 1009.3 is amended as follows: On line six of Exception 5 delete "7.75" and replace it with "8". On line seven of Exception 5 delete "10" and replace it with "9".

6.11.3 IFC, Chapter 10, Section 1009.11, Exception 4 is deleted and replaced with the following: 4. In occupancies in Group R-3, as applicable in Section 101.2 and in occupancies in Group U, which are accessory to an occupancy in Group R-3, as applicable in Section 101.2, handrails shall be provided on at least one side of stairways consisting of four or more risers.

6.11.4 IFC, Chapter 10, Section 1009.11.3 is amended to add the following: Exception: Non-circular handrails serving an individual unit in a Group R-1, Group R-2 or Group R-3 occupancy shall be permitted to have a maximum cross sectional dimension of 3.25 inches (83 mm) measured 2 inches (51mm) down from the top of the crown. Such handrail is required to have an indentation on both sides between 0.625 inch (16mm) and 1.5 inches (38mm) down from the top or crown of the cross section. The indentation shall be a minimum of 0.25 inch (6mm) deep on each side and shall be at least 0.5 (13mm) high. Edges within the handgrip shall have a minimum radius of 0.0625 inch (2mm). The handrail surface shall be smooth with no cusps so as to avoid catching clothing or skin.

6.11.5 IFC, Chapter 10, Section 1012.2 is amended to add the following exception: 3. For occupancies in Group R-3 and within individual dwelling units in occupancies in Group R-2, as applicable in Section 101.2, guards shall form a protective barrier not less than 36 inches (914mm).

6.11.6 IFC, Chapter 10, Section 1027.2 is amended to add the following: On line

five after the word "fire" add the words "and building".

6.12 Fireworks

6.12.1 IFC, Chapter 33, Section 3301.1.3 is amended to add the following Exception: 10. The use of fireworks for display and retail sales is allowed as set forth in UCA 53-7-220 and UCA 11-3-1.

6.13 Flammable and Combustible Liquids

6.13.1 IFC, Chapter 34, Section 3404.4.3 is amended as follows: Delete 3403.6 on line three and replace it with 3403.4.

6.14 Liquefied Petroleum Gas

6.14.1 IFC, Chapter 38, Section 3809.12, is amended as follows: Delete 20 from line three and replace it with 10.

6.14.2 IFC, Chapter 38, Section 3809.14 is amended as follows: Delete 20 from line three and replace it with 10.

R710-9-7. Fire Advisory and Code Analysis Committee.

7.1 There is created by the Board a Fire Advisory and Code Analysis Committee whose duties are to provide direction to the Board in the matters of fire prevention and building codes.

7.2 The committee shall serve in an advisory position to the Board, members shall be appointed by the Board, shall serve for a term of three years, and shall consist of the following members:

7.2.1 A representative from the State Fire Marshal's Office.

7.2.2 The Code Committee Chairman of the Fire Marshal's Association of Utah.

7.2.3 A fire marshal or fire inspector from a local fire department or fire district.

7.2.4 A representative from the Department of Health.

7.2.5 The Chief Elevator Inspector from the Utah Labor Commission.

7.2.6 A representative from the Department of Human Services.

7.3 This committee shall join together with the Uniform Building Code Commission Fire Protection Advisory Committee to form the Unified Code Analysis Council.

7.4 The Council shall meet as directed by the Board or as directed by the Building Codes Commission or as needed to review fire prevention and building code issues that require definitive and specific analysis.

7.5 The Council shall select one of it's members to act in the position of chair and another to act as vice chair. The chair and vice chair shall serve for one year terms on a calendar year basis. Elections for chair and vice chair shall occur at the meeting conducted in the last quarter of the calendar year.

7.6 The chair or vice chair of the council shall report to the Board or Building Codes Commission recommendations of the Council with regard to the review of fire and building codes.

R710-9-8. Enforcement of the Rules of the State Fire Marshal.

8.1 Fire and life safety plan reviews of new construction, additions, and remodels of state owned facilities shall be conducted by the SFM, or his authorized deputies. State owned facilities shall be inspected by the SFM, or his authorized deputies.

8.2 Fire and life safety plan reviews of new construction, additions, and remodels of public and private schools shall be completed by the SFM, or his authorized deputies, and the LFA.

8.3 Fire and life safety plan reviews of new construction, additions, and remodels of publicly owned buildings, privately owned colleges and universities, and institutional occupancies, with the exception of state owned buildings, shall be completed by the LFA. If not completed by the LFA, the SFM, or his authorized deputies shall complete the plan review.

8.4 The following listed occupancies shall be inspected by the LFA. If not completed by the LFA, the SFM, or his authorized deputies shall inspect.

8.4.1 Publicly owned buildings other than state owned buildings as referenced in 9.1 of this rule.

8.4.2 Public and private schools.

8.4.3 Privately owned colleges and universities.

8.4.4 Institutional occupancies as defined in Section 9-2 of this rule.

8.4.5 Places of assembly as defined in Section 9-2 of this rule.

8.5 The Board shall require prior to approval of a grant the following:

8.5.1 That the applying fire agency be actively participating in the statewide fire statistics reporting program.

8.5.2 The Board shall also require that the applying fire agency be actively working towards structural or wildland firefighter certification through the Utah Fire Service Certification System.

R710-9-9. Fire Prevention Board Budget and Amendment Sub-Committees.

9.1 There is created two Fire Prevention Board Sub-Committees known as the Budget Subcommittee and the Amendment Subcommittee. The subcommittees membership shall be appointed from members of the Board.

9.2 Membership on the Sub-Committee shall be by appointment of the Board Chair or as volunteered by Board members. Membership on the Sub-Committee shall be limited to four Board members.

9.3 The Sub-Committee shall meet as necessary and shall vote and appoint a chair to represent the Sub-Committee at regularly scheduled Board meetings.

R710-9-10. Repeal of Conflicting Board Actions.

All former Board actions, or parts thereof, conflicting or inconsistent with the provisions of this Board action or of the codes hereby adopted, are hereby repealed.

R710-9-11. Validity.

The Utah Fire Prevention Board hereby declares that should any section, paragraph, sentence, or word of this Board action, or of the codes hereby adopted, be declared invalid, it is the intent of the Utah Fire Prevention Board that it would have passed all other portions of this action, independent of the elimination of any portion as may be declared invalid.

R710-9-12. Adjudicative Proceedings.

12.1 All adjudicative proceedings performed by the agency shall proceed informally as set forth herein and as authorized by UCA, Sections 63-46b-4 and 63-46b-5.

12.2 If a city, county, or fire protection district refuses to establish a method of appeal regarding a portion of the IFC, the appealing party may petition the Board to act as the board of appeals.

12.3 A person may request a hearing on a decision made by the SFM, his authorized deputies, or the LFA, by filing an appeal to the Board within 20 days after receiving final decision.

12.4 All adjudicative proceedings, other than criminal prosecution, taken by the SFM, his authorized deputies, or the LFA, to enforce the Utah Fire Prevention and Safety Act and these rules, shall commence in accordance with UCA, Section 63-46b-3.

12.5 The Board shall act as the hearing authority, and shall convene as an appeals board after timely notice to all parties involved.

12.6 The Board shall direct the SFM to issue a signed order to the parties involved giving the decision of the Board within a reasonable time of the hearing pursuant to UCA, Section 63-46b-5(i).

12.7 Reconsideration of the Board's decision may be requested in writing within

20 days of the date of the decision pursuant to UCA, Section 63-46b-13.

12.8 Judicial review of all final Board actions resulting from informal adjudicative proceedings is available pursuant to UCA, Section 63-46b-15.

KEY: fire prevention, law

Date of Enactment or Last Substantive Amendment: March 6, 2006

Notice of Continuation: June 12, 2002

Authorizing, and Implemented or Interpreted Law: 53-7-204